

**2018 Annual Drinking Water Quality Report
Town of White Lake
PWS ID# 03-09-030**

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality of the water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from three ground wells that draw from the Black Creek Aquifer. The first well is located at Louise Street, the second is located at the North Carolina Department of Correction, and the third is at the old airport in the area of the intersection of Hwy 701 and SR 1515.

We are pleased to report that our drinking water is safe and meets federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact **Timothy F. Frush Public Works Director Town of White Lake at 910-862-4800**. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings held on **the second Tuesday of each month at 7:00 PM in the Town Hall meeting room**.

The Town of White Lake routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31, 2018 and the last test results of contaminants that were not due to be tested in 2018.

What EPA Wants You to Know

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; and radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Source Water Assessment Program (SWAP) Results

The North Carolina Department of Environment and Natural Resources (DENR), Public Water Supply (PWS) Section, Source Water Assessment Program (SWAP) conducted assessments for all drinking water sources across North Carolina. The purpose of the assessments was to determine the susceptibility of each drinking water source

(well or surface water intake) to Potential Contaminant Sources (PCSs). The results of the assessment are available in SWAP Assessment Reports that include maps, background information and a relative susceptibility rating of Higher, Moderate or Lower.

The relative susceptibility rating of each source for the Town of White Lake was determined by combining the contaminant rating (number and location of PCSs within the assessment area) and the inherent vulnerability rating (i.e., characteristics or existing conditions of the well or watershed and its delineated assessment area.). The assessment findings are summarized in the table below:

Susceptibility of Sources to Potential Contaminant Sources (PCSs)

| Source Name | Susceptibility Rating | SWAP Report Date |
|-------------|-----------------------|------------------|
| Well # 1 | Lower L | July 01, 2018 |
| Well #2 | Lower L | July 01, 2018 |
| Well #3 | Lower L | July 01, 2018 |

The complete SWAP Assessment report for the Town of White Lake may be viewed on the Web at: <http://www.deh.enr.state.nc.us/pws/swap> Please note that because SWAP results and reports are periodically updated by the PWS Section, the results available on this web site may differ from the results that were available at the time this CCR was prepared. To obtain a printed copy of this report, please mail a written request to: Source Water Assessment Program – Report Request, 1634 Mail Service Center, Raleigh NC 27699-1634, or email request to swap@ncmail.net. Please indicate your system name, PWSID, and provide your name, mailing address and phone number. If you have any questions about the SWAP report please contact the Source Water Assessment staff by phone at 919-715-2633. It is important to understand that a susceptibility rating of “higher” **does not** imply poor water quality, only the systems’ potential to become contaminated by PCS’s in the assessment area.

Water Quality Data Table of Detected Contaminants

We routinely monitor for over 150 contaminants in your drinking water according to Federal and State laws. The table below lists all the drinking water contaminants that we detected in the last round of sampling for the particular contaminant group. The presence of contaminants does not necessarily indicate that water poses a health risk. **Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2018.** The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

Important Drinking Water Definitions:

Not-Applicable (N/A) – Information not applicable/not required for that particular water system or for that particular rule.

Non-Detects (ND) - Laboratory analysis indicates that the contaminant is not present at the level of detection set for the particular methodology used.

Parts per million (ppm) or Milligrams per liter (mg/L) - One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (ug/L) - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Extra Note: MCLs are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Inorganic Contaminants

| Contaminates | Sample Date | MCL Violations Y/ N | Your Water | Range Low High | MCLG | MCL | Likely Source of Contamination |
|----------------|-------------|---------------------|------------|----------------|---------|---------|---|
| Fluoride (ppm) | 2016 | N | .20 ppm | .12-.28 ppm | 4.0 ppm | 4.0 ppm | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |

Lead and Copper Contaminants

| Contaminant (units) | Sample Date | Your Water | # of sites found above the AL | MCLG | MCL | Likely Source of Contamination |
|--|-------------|------------|-------------------------------|--------|-----------|--|
| Copper (ppm) (90 th percentile) | July 2017 | .218 ppm | 0 | 1.3ppm | AL=1.3ppm | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |
| Lead (ppb) (90 th percentile) | July 2017 | N/D | 0 | 0 | AL=15ppb | Corrosion of household plumbing systems, erosion of natural deposits |

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of White Lake is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential of lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://epa.gov/safewater/lead>.

Volatile Organic Chemical (VOC) Contaminants

| Contaminates | Sample Date | MCL Violations Y/ N | Your Water | Range Low High | MCLG | MCL | Likely Source of Contamination |
|----------------------------------|-------------|---------------------|------------|----------------|------|-----|---|
| Tetrachloroethylene (ppb) | 7/18 | N | 4.7 | 0-4.7 | 0 | 5 | Discharge from factories and dry cleaners |
| 1,1,1Tetrachloroethylene - (ppb) | 7/18 | N | .7 | 0-.7 | 0 | 200 | Discharge from metal degreasing sites and other factories |

Disinfectants and Disinfection Byproducts Contaminants

| Contaminant (units) | MCL/MRDL Violation Y/N | Your Water (AVG) | Range Low High | MC LG | MCL | Likely Source of Contamination |
|--|------------------------|------------------|----------------|-------|--------|---|
| TTHM (ppb) [Total Trihalomethanes] | N | .37 ppb | .0-51 ppb | N/A | 80 ppb | By-product of drinking water chlorination |
| HAA5 (ppb) [Total Haloacetic Acids] | N | .12 ppb | 0-22 ppb | N/A | 60 ppb | By-product of drinking water disinfection |

Secondary Contaminates, required by the NC Public Water Supply Section, are substances that affect the taste, odor, and / or color of drinking water. These aesthetic contaminates normally do not have any health effects and normally do not affect the safety of your water.

Water Characteristics Contaminants

| Contaminant (units) | Sample Date | Your Water | Range Low/High | Secondary MCL |
|---------------------|-------------|------------|----------------|---------------|
| Manganese (ppm) | 07/2016 | .041 ppm | N/A | 0.05ppm |
| Sodium (ppm) | 07/2016 | 97.81 ppm | N/A | N/A |
| Sulphate | 07/2016 | 34.3 ppm | N/A | N/A |
| Iron | 07/20/16 | .115 ppm | N/A | N/A |

The Town of White Lake Public Works Department works around the clock to provide top quality water to every tap. We ask that you help us protect our water sources, which are the heart of our community, our way of life and our children's future.